

## **QUESTIONS AND ANSWERS**

### **RFQ – SHO80016Q0010**

#### **Swimming Pool & Fountains Maintenance**

- Dimensions of pools.  
Ambassador's residence 13 mts x 7.5 mts average depth 1.70 mts.  
Marine House 9 mts x 5 mts average depth 1.50 mts  
DCM 6 mts x 4mts average depth 1.50 mts.
- The CMR pool litres.  
150,000.00 litres
- Type of filtration of swimming pools and fountains.  
All of the pools filtration sand silica and fountains will have to be use auxiliary equipment includes (pump, filter, hoses, brushes)
- Pools and Fountains equipment.  
(pump, filter, hoses, brushes ) All of these equipment must be permanent in each pool.
- Hours and days of services.

See SOW numeral 6.1 for amount of minimum visits per week. Notice that contract is a performance based contract and more visits may be required as stated in the SOW.

See SOW 9.0 for the allowed working hours at each pool site.

- The fish species.  
  
Goldfish y Blackmore.
- Dimensions of the Fountains.  
  
2 mts x 2 mts average depth 0.5 mts.
- Chemical previously used or accepted.

See SOW 6.5 Only EPA registered sanitizer systems and chemicals shall be used.